



**BIONOR Sp. z o.o.**

**ul. Ściegiennego 26 25-114 Kielce**

**13**

**EN 12566-3**

Packaged domestic wastewater treatment plant  
for treatment of domestic wastewater

- Product's reference code : **BIONOR B-5**

- Material : **PE**

**Effectiveness of treatment :**

Treatment efficiency ratios ( at tested organic daily load BOD <sub>5</sub> - 0,355 kg/d	BOD <sub>5</sub>	97,6%	7,8 mg/l
	COD	93,7%	45,5 mg/l
	SS	93,4%	20,2 mg/l
	Ntot	71,7%	15,9 mg/l
	P	95,0%	0,3 mg/l

**Treatment capacity (nominal designation) :**

- Nominal organic daily load ( BOD <sub>5</sub> )	0,36 kg/d
- Nominal hydraulic daily flow ( Q <sub>N</sub> )	1 m <sup>3</sup> /d
<b>Watertightness: ( water test )</b>	Pass
<b>Crushing resistance: ( pit test )</b>	NPD
<b>Electrical consumption :</b>	1,39 kWh/d

Performance tested by :

Date tests completed - June 2013

Statybos Produkcijos Sertifikavimo Centras

Linkmenu str. 28

LT-08217 Vilnius , Lithuania

President Zbigniew Dyk

**BIONOR Sp. z o.o.**  
ul. Ściegiennego 26  
25-114 Kielce  
Tel./fax 041 348 33 03  
NIP 667-10-23-316 REGON 290592843

